



Lead Consulting and Inspection, Inc.

MAR 25 2022

NJ Dept. of Health Lead Permits
Inspector/Risk Assessor #001615
Plan/Designer #001609
Supervisor/Housing & Public Building #001537
Supervisor/Commercial Bldg. & Steel Structures #007837
NJ Dept. of Community Affairs Lic. #00121-E

Water Certification

Name: Newark Day Center
305 Halsey Street
Newark, NJ 07102
Phone:

Inspection Address: 305 Halsey Street
Newark, NJ 07102

Inspection date: January 28, 2022

Water Outlet Tested:	1 st floor / Kitchen / Sink	Pass	Pass
	1 st floor / Kitchen / Hand washing sink	Pass	
	1 st floor / Cafeteria / Water fountain		Pass
	Group 7 / Left sink		Pass
	1 st floor / Toddler 2 / Left sink		Pass
	Group 8 / Bath / Sink		Pass
	Group 7 / Boys / Sink		Pass
	Group 7 / Girls / Sink		Pass
	Toddlers 5 / Bath sink		Pass
	Toddlers 5 / Classroom sink		Pass
	1 st floor / Infants / Sink		Pass
	Toddlers 1 / Classroom / Sink		Pass
	Toddlers 1 / Bath / Sink		Pass
	1 st floor / Office / Water cooler		Pass
	Group 5 / Boys room / Sink		Pass
	Group 5 / Girls room / Middle sink		Pass

EPA Standard: Copper <1300 PPB Lead <15 PPB

Certification: Drinking water meets EPA Standards
See reports from (*Environmental Hazard Services, LLC.*)

Operator License: 00121-E

G. Luke Schroeder
NJ dept of Health ID# 001537